

เอกสารแสดงค่าการทำความร้อน

(Thermal Conductivity)



TEST REPORT

Department of Science Service

Sample's name

Laboratory No.

Q-BRICKS

Mark / Brand Q-BRICKS

DepartmL52/09795 Jience Service

Test Result

Thermal Conductivity, W/m.K

0.190

Customer's name

KITTICHAI WASADUPHAN PART., LTD.

Customer's address

59/1 MOO2 MITRAPARP RD. , TALINGCHAN, MUEANG, SARABURI

Sample's description

Grey concrete size: 1 x 1 ft and 2.5 cm. thickness partment of Science

Test date

12 November 2009

Test method

ASTM C-177-97

Department of Science Ser

Department of Science Service Reported by

R My/L
(Mr. Puckanai Thongthiumporn)

Scientist, Senior Professional Level

Scientist, Senior Professional Level

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be reproduced or shall not manifest partially without the written permission of the Department of Science Service.

Department of Science Service, Ministry of Science and Technology Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Page 2/2



TEST REPORT

Department of Science Service

Sample's name

Mark / Brand

Laboratory No.

Q-BRICKS

Q-BRICKS

DepartmL52/097939ience Service

Test Result

Department of Science Service

Thermal Conductivity, W/m.K

0.190

Customer's name

KITTICHAI WASADUPHAN PART., LTD.

Customer's address

59/1 MOO2 MITRAPARP RD. , TALINGCHAN, MUEANG, SARABURI Grey concrete size: 1 x 1 ft and 2.5 cm. thickness partment of Science Service

Sample's description

Test date .

12 November 2009

Test method

ASTM C-177-97

Department of Science Service

Department of Science Servic Reported by

R Myth (Mr. Puckanai Thongthiumporn)

Scientist, Senior Professional Level

Scientist, Senior Professional Level

This report is only valid for the sample received. The above statement is not intended for advertising purposes and shall not be reproduced or shall not manifest partially without the written permission of the Department of Science Service.

Department of Science Service, Ministry of Science and Technology Rama VI Road, Ratchathewi, Bangkok 10400, Thailand

Page 2/2